

### ZERTIFIKAT **CERTIFICATE**



#### No.BVPMS\_7167

Genehmigungsinhaber Zhejiang ETEK Electrical technology CO., LTD

Holder NO.288 Wei17th Road, Yueqing Economic Development Zone, Yueqing,

Wenzhou, Zheijang Province - CHINA

Fertigungsstätte Zhejiang ETEK Electrical technology CO., LTD (N°26611)

Manufacturing site NO.288 Wei17th Road, Yueqing Economic Development Zone, Yueqing,

Wenzhou, Zheijang Province - CHINA

Gültig bis Aktenzeichen Ausstellungsdatum File No. Date of delivery Expired on **BVPMS\_7167** 23/02/2022 22/02/2027

Geprüft nach / Tested in conformity with EN 60947-1:2007 +A1:2011 +A2:2014 EN 60947-2:2017 + A1:2020

B210095 Testbericht Nr. / Test report No

Produkt / Product Miniature Circuit Breaker

Modell / Model EKM3-63

Siehe Anhange / See Annex

Nominalwerte / Rated characteristics Siehe Anhange / See Annex

Markenname / Brand name

Auch geprüft nach / Also tested in conformity with IEC 60947-1:2007 Weitere Angaben / Additional information

+A1:2010+A2:2014 and IEC 60947-2:2016 + A1:2019.

Dieser Genehmigung liegen unsere Prüf- und Zertifizierungsregeln zugrunde. The present approval is submitted to our Testing and Certification rules.

Zertifizierungsstelle erfüllt ISO/IEC 17065. Certification Body complies with ISO/IEC 17065

Fontenay-aux-Roses, 23/02/2022

Didier BOURGES

Certification



Manager of



LCIE



## Anhang für Zertifikate / Annex of certificate n° BVPMS\_7167

### Product references list

1P	2P	3P	4P
011	012	013	014
021	022	023	024
031	032	033	034
041	042	043	044
051	052	053	054
061	062	063	064
081	082	082	084
101	102	102	104
131	132	132	134
161	162	162	164
201	202	202	204
251	252	252	254
321	322	322	324
401	402	402	404
501	502	502	504
631	632	632	634
	011 021 031 041 051 061 081 101 131 161 201 251 321 401 501	011     012       021     022       031     032       041     042       051     052       061     062       081     082       101     102       131     132       161     162       201     202       251     252       321     322       401     402       501     502	011     012     013       021     022     023       031     032     033       041     042     043       051     052     053       061     062     063       081     082     082       101     102     102       131     132     132       161     162     162       201     202     202       251     252     252       321     322     322       401     402     402       501     502     502



Laboratoire Central des Industries Electriques

Une société de Bureau Veritas



# Anhang für Zertifikate / Annex of certificate n° BVPMS\_7167

Utilization category	A	
Interruption medium	Air	
Design	Moulded case	
Method of controlling the operating mechanism	Dependent manual	
Suitability for isolation	Suitable	
Provision for maintenance	Non-maintainable	
Method of installation	Fixed	
Protection degree :	IP20 for front cover	
Rated operational voltage Ue : (V)	230V~ or 240V~(1P);400V or 415V~(2P/3P/4P)	
Rated insulation voltage Ui: (V)	500V	
Rated impulse withstand voltage Uimp: (V)	6kV	
Rated current le : (A)	1A;2A;3A;4A;5A;6A;8A;10A;13A;16A;20A;25A;32A;40A;50A;63A	
Conventional free air thermal current 1th: (A)	63A	
Conventional enclosed thermal current Ithe: (A)	N/A	
Rated current for four pole circuit-breakers: (A)	63A	
Rated frequency: (Hz)	50/60Hz	
Nature of supply:	~	
Total number of poles :	1P;2P;3P;4P	
Number of protected poles :	1P;2P;3P;4P	
Rated duty	Uninterrupted duty	
Rated short-time making capacity Icm: (A)	10.2kA	
Rated ultimate short-circuit breaking capacity lcu: (A)	6kA	
Rated service short-circuit breaking capacity Ics: (A)	6kA	
Rated short-time withstand current lcw: (A)	N/A	
Electrmagnetic compatibility	Thermo-magnetic	
Instantaneous tripping current:	10ln	
Reference ambient calibration air temperature : (°C)	30°C	
Pollution degree	2	
Material group:	Illa	
safety distance (short-circuit tests) :	Back:0mm Front:0mm Up:50mm Down:50mm Left:0mm Right:0mm	



LCIE