

FR_709885/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark / Brand (if any)

Model / Type Ref.

Customer's Testing Facility (CTF) Stage used

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Switch

Changeover switch

ZHEJIANG ETEK Electrical technology CO.,LTD

NO.288 Wei17th Road, Yueqing Economic Development Zone

Yueqing, Wenzhou Zheijang Province - China

ZHEJIANG ETEK Electrical technology CO.,LTD

NO.288 Wei17th Road, Yueqing Economic Development Zone

Yueging, Wenzhou Zheijang Province - China

ZHEJIANG ETEK Electrical technology CO.,LTD

NO.288 Wei17th Road, Yueqing Economic Development Zone

Yueqing, Wenzhou Zheijang Province - China

☐ Additional Information on page 2

See Annex

етэк

See Annex

Supersedes CBTC FR_709885 dated 16/11/2020. Change or modification of the design

☐ Additional Information on page 2

IEC 60947-3:2020

IEC 60947-1:2020

B210059

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE 33 avenue du Général Leclerc 92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr

Date: 08/09/2021

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES

RCS Nanterre B 408 363 174
33 avenue du G. S. G. D. Sture: Julien Gauthier F - 92266 FONTENAY AUX ROSKS ertification Officer



FR_709885/M1

ANNEX

References, ratings and main characteristics:

	1P	2P	3P	4P
40A	1P 40A	2P 40A	3P 40A	4P 40A
32A	1P 32A	2P 32A	3P 32A	4P 32A
25A	1P 25A	2P 25A	3P 25A	4P 25A
16A	1P 16A	2P 16A	3P 16A	4P 16A

Technical Characteristics		
Utilization category	AC-22A	
Method of operation	Dependent manual operation	
Suitability for isolation	Not Suitable	
Protection degree :	IP20 for front cover	
Number of poles :	4P/3P/2P/1P	
Kind of current :	AC	
Rated operational voltage Ue : (V)	240/415V for 1P; 415V for 2P/3P/4P	
Rated insulation voltage Ui : (V)	415V	
Rated impulse withstand voltage Uimp: (V)	4kV	
Conventional free air thermal current Ith: (A)	40A	
Rated operational current le : (A)	40A;32A;25A;16A	
Rated ininterrupted current lu : (A)	40A;32A;25A;16A	
Rated short-time withstand current : Icw (A)	480A/1s	
Rated short-circuit making capacity: Icm (A)	800A	
Control circuits :	N/A	
Auxiliary circuits :	N/A	



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE 33 avenue du Général Leclerc 92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr

Date: 08/09/2021

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A. S. au capital de 15.745.984 €
RCS Nanterro B 408.363.174
RCS Nanterro B 408.363.174
33 avenue du General Discussion Conficer
F - 92266 FONTENAY AUX ROSES Certification Officer