

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)

Name and address of the applicant

Zhejiang ETEK Electrical technology Co., Ltd.
No.288 Wei 17th Road, Yueqing Economic Development Zone,
Yueqing, Wenzhou, Zhejiang Province, P.R.China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

Un= 230/240V~, 1P+N, 50/60Hz
In= 6, 10, 16, 20, 25, 32, 40A, C-&B-type
IΔn= 10, 30, 100, 300mA, type-AC&-A
Icn= Ics= 6000A, Energy limiting class 3

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

EKL7-40

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 61009-1:2010+A1+A2
IEC 61009-2-2:1991

As shown in the Test Report Ref. No. which forms part of this Certificate

211201156SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden



Signature:



Leif Mattsson

Date: 01 March, 2022