

FR 709050

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE Product Circuit-breaker for overcurrent protection for household and similar installations ZHEJIANG ETEK Electrical technology CO.,LTD Name and address of the applicant NO.288 Wei17th Road, Yueqing Economic Development Zone Yueqing, Wenzhou, Zheijang Province - CHINA Hangzhou Taimu Electrical Co., Ltd. Name and address of the manufacturer No. 157 Longchuanwu Rd., Qianjiang Economic Development Area, 311100 Hangzhou, Zhejiang - CHINA Name and address of the factory Hangzhou Taimu Electrical Co., Ltd. No. 157 Longchuanwu Rd., Qianjiang Economic Development Area, 311100 Hangzhou, Zhejiang - CHINA Note: When more than one factory, please report on page 2 ☐ Additional Information on page 2 Ratings and principal characteristics See Annex Trademark / Brand (if any) етэк Customer's Testing Facility (CTF) Stage used **EKM2-32N** Model / Type Ref. See Annex Additional information (if necessary may also be reported on page 2) ☐ Additional Information on page 2 A sample of the product was tested and found to IEC 60898-1:2015(ed.2) be in conformity with As shown in the Test Report Ref. No. which B200045 forms part of this Certificate



LCIE - Laboratoire Central des Industries Electriques 33, avenue du Général Leclerc - BP8 FR 92 266 Fontenay aux Roses Cedex

This CB Test Certificate is issued by the National Certification Body

www.lcie.fr

Date: 22/07/2020

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES

S.A.S. au capital do 15.745.984 €
S.A.S. au capital do 15.745.984 €
S.A.S. Sau capital do 15.745.984 €
S.A.S. au capital do 15.745.984 €
S.A.S



FR_709050

ANNEX

References, ratings and main characteristics:

Enclosure Type 2 Icn1=Icn=Ics=6000A 1P+N (neutral on left)				
	Туре В	Type C	Type D	
1A	01B4	01C4	01D4	
2A	02B4	02C4	02D4	
3A	03B4	03C4	03D4	
4A	04B4	04C4	04D4	
6A	06B4	06C4	06D4	
10A	10B4	10C4	10D4	
16A	16B4	16C4	16D4	
20A	20B4	20C4	20D4	
25A	25B4	25C4	25D4	
32A	32B4	32C4	32D4	

Enclosure Type 2 Icn1=Icn=10000A;Ics=7500A 1P+N (neutral on left)				
	Type B	Type C	Type D	
1A	01B6	01C6	01D6	
2A	02B6	02C6	02D6	
3A	03B6	03C6	03D6	
4A	04B6	04C6	04D6	
6A	06B6	06C6	06D6	
10A	10B6	10C6	10D6	
16A	16B6	16C6	16D6	
20A	20B6	20C6	20D6	
25A	25B6	25C6	25D6	
32A	32B6	32C6	32D6	



LCIE - Laboratoire Central des Industries Electriques 33, avenue du Général Leclerc - BP8 FR 92 266 Fontenay aux Roses Cedex

www.lcie.fr

Date: 23/07/2020

LABORATOIRE CENTRAL DES

LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745,984 €
RCS Nanterre B 408,363,174
33 avenue du Golg Nature:
F - 92266 FONTENAY AUX ROSESertification Officer



FR_709050

Rated operational voltage Ue : (V)	230V~(1P+N)
Rated current In : (A)	1;2;3;4;6;10;16;20;25;3 2A
Rated frequency : (Hz)	50/60Hz
Nature of supply :	~
Total number of poles :	1P+N
Number of protected poles :	1P
Rated insulation voltage Ui: (V)	500V
Rated impulse withstand voltage Uimp : (V)	4000V
Instantaneous tripping current :	D; C and B
Reference ambient calibration air temperature : (°C)	30
Rated short-circuit capacity Icn : (A)	6000A and 10000A
Rated making and breaking capacity on one pole separately lcn1: (A)	Same as Icn
Energy limiting class I2t:	3
Grid distance (short-circuit tests) :	45mm
Protection against external influences :	Enclosed
Protection degree :	IP20
Material group :	IIIa
Method of mounting :	On rail
Method of electrical connection	
not associated with the mechanical-mounting	
Type of terminals :	Pillar terminal
Nominal diameter of thread : (mm)	3,9mm
Operating means :	Lever



LCIE – Laboratoire Central des Industries Electriques 33, avenue du Général Leclerc – BP8 FR 92 266 Fontenay aux Roses Cedex

www.lcie.fr

Date: 23/07/2020

X Roses Cedex

LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408.363 174
33 avenue du General Grandure: Julien Gauthier
F - 92266 FONTENAY AUX ROSES Certification Officer