



Ref. Certif. No.

SE-96476

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Moulded case circuit-breakers (MCCB)

Name and address of the applicant

Zhejiang ETEK Electrical technology Co., Ltd.
No. 288 Wei 17th Road, Yueqing Economic Development Zone,
Yueqing, Wenzhou, Zhejiang Province, P. R. China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Shangtu Electrical technology Co., Ltd.
NO.268 Wei 20th Road, Yueqing Economic Development Zone,
Yueqing, Wenzhou, Zhejiang Province, P. R. China

Ratings and principal characteristics

See page 2

Trademark (if any)

ETEK

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

EKM8T-400S, EKM8T-400H, EKM8T-630S, EKM8T-630H

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016

-As shown in the Test Report Ref. No. which forms part of this Certificate

190702340SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 16 December 2019

intertek

Signature:

Henrik Wikström

Ratings and principal characteristics

Model:	EKM8T-400H, EKM8T-400S
Ue:	400V, 3P, 4P(3P+N)
Ratings Current(In):	250, 320, 400A; Ir=(0,7-1,0)In
Icu(kA):	50kA(EKM8T-400H), 35kA(EKM8T-400S)
Ics(kA):	35kA(EKM8T-400H), 25kA(EKM8T-400S)
Category:	Cat. A
Frequency:	50/60Hz
Other information:	Ui= 1000V~, Uimp=8kV, Ref. temperature: +40°C

Model:	EKM8T-630H, EKM8T-630S
Ue:	400V, 3P, 4P(3P+N)
Ratings Current(In):	500, 630A; Ir=(0,7-1,0)In
Icu(kA):	50kA(EKM8T-630H), 35kA(EKM8T-630S)
Ics(kA):	35kA(EKM8T-630H), 25kA(EKM8T-630S)
Category:	Cat. A
Frequency:	50/60Hz
Other information:	Ui= 1000V~, Uimp=8kV, Ref. temperature: +40°C

Date: 16 December 2019

 Signature: 